



Date of Issue: 05/08/2025 04:04:14

DEP Bureau of Laboratories - Harrisburg
P.O. Box 1467
2575 Interstate Drive
Harrisburg, PA 17105-1467

Contact Phone Number: (717) 346-7200

NELAP - accredited by

NJ DEP - Laboratory Number: PA059
PA DEP LAP - DEP Lab ID: 22-00223

Analytical Report For
Water Supply Management

Sample ID: 1366 042

Date Collected: 05/05/2025 09:26:00 AM

Lab Sample ID: B2025001416

Status: Completed

Name of Sample Collector: Tasha Dodge

Date Received: 05/06/2025

County: Tioga

State:

Municipality: Lawrenceville Boro

LAWRENCEVILLE BOROUGH WATER DEPARTMENT
6 MECHANIC ST
LAWRENCEVILLE PA. 169299768

Facility/Permit ID: 2590050

FIX ID: 4565

Facility: LAWRENCEVILLE BORO WATER DEPT

Sub-Facility: 001

FIX ID: 1267553

Name: DISTRIBUTION SYSTEM 001

Sample Medium: Ground Water

Sample Medium Type: Water

Location: Complainant Kitchen

Reason: Complaint

Project: NOT INDICATED

Standard Anlysis: B017

Matrix: Water

Field Tests		
Chlorine - Free	0.30	mg/L

Analytical Report For
Water Supply Management

Sample ID: 1366 042

Date Collected: 05/05/2025 09:26:00 AM

Lab Sample ID: B2025001416

Status: Completed

Legal Seal: H015283	Intact: Yes
---------------------	-------------

Stream Condition:

Sample Comment: H015283

Test Codes / CAS # - Description	Reported Results	Date And Time Analyzed	Approved by	Test Method
MMOECT E. coli MPN	<1.0 cf/100mL	05/06/2025 09:40 AM	ABMICKEY	SM 9223B
MMO-T Total Coliform MPN	<1.0 cf/100mL	05/06/2025 09:40 AM	ABMICKEY	SM 9223B

The results of the analyses provided in this laboratory report relate only to the sample(s) identified therein. Unless otherwise noted, the results presented on this laboratory report meet all requirements of the 2016 TNI standard. Sample was in acceptable condition when received by the Laboratory. Any exceptions are noted in the report.
* denotes tests that the laboratory is not accredited for

U - Indicates analysis was performed for the test but it was not detected. The sample quantitation limit is reported.

J - Indicates an estimated value, reported between Reporting Limit (RL) and Minimum Detection Limit (MDL).

Jennifer Fesler, Technical Director, Bureau of Laboratories